

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Verification Report UCR ID: 156



Title	250 kW Ground Mounted Solar Power Project By M/s Tara Solar Power PV Plant
Project Proponent	M/s Tara Solar Power PV Plant
Project Location	Village- Shamshi, Tehsil- Bhunter Kullu District, Himachal Pradesh, India. Latitude: 31°53'11"N Longitude :77°08'41"E
Verified By	Mr. Shardul Amin, Lead Verifier, Naturelink Solutions Pvt. Ltd. Email: audit@thenaturelink.in, Contact: +91- 7574804497
Date	01/02/2023

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

COVER PAGE	
Project Verification Report Form (VR)	
BASIC INFORMATION	
Name of approved UCR Project Verifier / Reference No.	Naturelink Solutions Pvt Ltd.
Type of Accreditation	☐ CDM Accreditation ☐ ISO 14065 Accreditation ☒ UCR Approved Verifier
Approved UCR Scopes and GHG Sectoral scopes for Project Verification	Sectoral Scope: 01 Energy Industries
Validity of UCR approval of Verifier	May 2022 onwards
Completion date of this VR	01/02/2023
Title of the project activity	250 kW Ground Mounted Solar Power Project By M/s Tara Solar Power PV Plant
Project reference no. (as provided by UCR Program)	156
Name of Entity requesting verification service (can be Project Owners themselves or any Entity having authorization of Project Owners, example aggregator.)	Creduce Technologies Private Limited (Aggregator)
Contact details of the representative of the Entity, requesting verification service (Focal Point assigned for all communications)	Shailendra Singh Rao Mobile: +91-9016850742 Address: 2-O-13,14 Housing Board Colony, Banswara, Rajasthan - 327001, India.
Country where project is located	India
Applied methodologies (Approved methodologies by UCR Standard used)	AMS-I.D.: "Grid connected renewable electricity generation", version 18

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Project Verification Criteria: Mandatory requirements to be assessed	☒ UCR Standard ☒ Applicable Approved Methodology ☐ Applicable Legal requirements /rules of host country ☒ Eligibility of the Project Type ☒ Start date of the Project activity ☒ Meet applicability conditions in the applied methodology ☒ Credible Baseline ☒ Do No Harm Test ☒ Emission Reduction calculations ☒ Monitoring Report ☒ No GHG Double Counting ☐ Others (please mention below)
Project Verification Criteria: Optional requirements to be assessed	☒ Environmental Safeguards Standard and do-no-harm criteria ☐ Social Safeguards Standard do-no-harm criteria
Project Verifier's Confirmation: The <i>UCR Project Verifier</i> has verified the UCR project activity and therefore confirms the following:	The UCR Project Verifier Naturelink Solution Pvt. Ltd., certifies the following with respect to the UCR Project Activity "250 kW Ground Mounted Solar Power Project By M/s Tara Solar Power PV Plant". ☒ The project aggregator has correctly described the Project Activity in the Project Concept Note 2.0 (dated 23/01/2023) including the applicability of the approved methodology A.M.S I. D and meets the methodology applicability conditions and has achieved the estimated GHG emission reductions, complies with the monitoring methodology and has calculated emission reductions estimates correctly and conservatively.

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

	☒ The project activity is likely to generate GHG emission reductions amounting to the estimated 481 tCO₂e, as indicated in the monitoring report, which are additional to the reductions that are likely to occur in absence of the Project Activity and complies with all applicable UCR rules, including ISO 14064-2 and ISO 14064-3. ☒ The project activity is not likely to cause any net-harm to the environment and/or society ☒ The project activity complies with all the applicable UCR rules and therefore recommends UCR Program to register the Project activity with above mentioned labels.
Project Verification Report, reference number and date of approval	Verification Report UCR ID: 156 Date: 01/02/2023
Name of the authorised personnel of UCR Project Verifier and his/her signature with date	 Mr. Shardul Amin Lead Verifier Naturelink Solution Pvt. Ltd. Date: 01/02/2023

Project Verification Report

A. Executive Summary

The verification work has been contracted by project aggregator Creduce Technologies Pvt Ltd to perform an independent verification of its UCR project titled “**250 kW Ground Mounted Solar Power Project By M/s Tara Solar Power PV Plant UCR approved project ID:156**”, to establish a number of CoUs generated by the project over the crediting period from 26/04/2021 to 31/12/2022 (both days included).

Verification for the period : 26/04/2021 to 31/12/2022

In my opinion, the total GHG emission reductions over the crediting/verification period stated in the Monitoring Report (MR), submitted to me is found to be correct and in line with the UCR guidelines.

The GHG emission reductions were calculated on the basis of UCR Protocols which draws reference from, Standard Baseline, AMS. I. D – Grid connected renewable electricity generation (Version 18.0). Owing to the Covid pandemic, the verification was done remotely by way of video calls, phone calls, and submission of documents for verification through emails.

I am able to certify that the emission reductions from the 250 kW Ground Mounted Solar Power Project By M/s Tara Solar Power PV Plant (UCR ID – 156) for the period 26/04/2021 to 31/12/2022 amounts to 481 CoUs (481 tCO₂e).

Scope

The scope of the verification is the independent, objective review and ex-post determination of the monitored reductions in GHG emission by the project activity.

1. The quality of data management and records of underlying data;
2. Completeness and accuracy of calculations and baseline emission reports;
3. Proper inclusion and documentation of all project locations,
4. Correct application of offset rules for filling baseline period data gaps;
5. Other data, methods, and procedures deemed necessary to establish the accuracy of emission reductions.
6. Agreement stating Assurance to avoid double accounting for the project to be verified, along with required proof.

The project is assessed against the requirements of the UCR programme verification Guidance Document, UCR Standard, UCR Programme Manual and related rules and guidelines. Due professional care has been exercised and ethical conduct has been followed by the assessment team during the verification process. The verification report is a fair presentation of the verification activity. The validation of project is not part of present assignment and projects deemed validated post registration by UCR.

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Description of the Project

As described in the Project Concept Note (PCN), the project activity involves installation and operation of solar PV power project of total 0.25 MW. The project is located at Shamsi village, in Kullu district, in the state of Himachal Pradesh, in India.

The technical specification of the project is as follows;

Parameter	Specification
Total number of Photovoltaic Modules	657
Rating of Photovoltaic Module	380 Wp
Module make	Canadian
Technology	Bifacial mono n-type
No. of Inverter/Capacity	5 (60 kWp*4 + 10 kWp*1)

As mentioned in the monitoring report and emission reduction calculation sheet submitted for verification, the project replaces anthropogenic emissions of greenhouse gases (GHGs) estimated to be approximately 481 tCO₂e for the said period under verification, there on displacing 536 MWh amount of electricity from the generation mix of power plants connected to the Indian electricity grid, which is mainly dominated by the fossil-fuel based power plant. The project activity is a grid-connected renewable energy generation project having a capacity of less than 15 MW. The project is a small-scale activity. The methodology applied in the monitoring report is verified against the A.M.S I. D “Grid connected renewable electricity generation” version 18.0.

Verified total emission reductions achieved through the project activity during the monitoring period is summarised below:

Summary of the Project Activity and ERs Generated for the Monitoring Period	
Start date of this Monitoring Period	26/04/2021
Carbon credits claimed up to	31/12/2022
Total ERs generated (tCO ₂ e)	481 tCO ₂ e
Leakage emission	0
Project Emission	0

B. Project Verification team, technical reviewer and approver:

No.	Role	Last name	First name	Affiliation	Involvement in		
					Doc review	Off-Site inspection	Interviews
1.	Lead Verifier & Technical Expert	Amin	Shardul	Naturelink Solution Pvt Ltd.(UCR approved Verifier)	Yes	No	Yes

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

C. Means of Project Verification

C.1 Desk/document review

The project documents submitted to UCR approved verifier Naturelink Solution Pvt. Ltd. was reviewed by the technical expert and by the lead verifier. The documents reviewed involves verification of the legal status of individual project owner for consistency, project related documents like installation and commissioning of equipment used in project activity. Environmental clearances from state or central pollution control board Consent to establish and operate, monitoring related meters/parameters equipment measuring instruments and their calibration records, to establish running of equipment for the crediting period.

The PCN is made available to the verifier post approval by UCR which is considered as validated documents and the content of validated PCN is considered as record wherever required. Further, the communication agreement made between the project owner and the project aggregator is a document of the UCR registry hence the project aggregator is treated as an authorized representative of the project owner. All the documents submitted by the project aggregator to the verifier are treated as documents submitted on behalf of the project owner.

The list of submitted documents is available in a subsequent section of this verification report under the section “Document reviewed or referenced”-section I.

C.2 On-Site inspection- Not applicable.

Date of off-site inspection: DD/MM/YYYY to DD/MM/YYYY	Not applicable as per UCR guideline site visit not conducted for this verification activity.		
No.	Activity performed Off-Site	Site location	Date
1.			

C.3 Interviews:

As per UCR guidelines, the site visit was not conducted during the course of verification and the only interview was conducted.

No.	Interview			Date	Subject
	Last name	First name	Affiliation		

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

1.	Solanki	Rahul	Project In-charge, M/s Tara Solar Power PV Plant	31/01/2023	Project Overview and JMRs, Calibration Report
----	---------	-------	--	------------	---

C.4 Sampling approach: Not Applicable

C.5 Clarification requests (CLs), corrective action requests (CARs) and forward action requests (FARs) raised

Areas of Project Verification findings	No. of CL	No. of CAR	No. of FAR
Green House Gas (GHG)			
Identification and Eligibility of project type	NIL	NIL	NIL
General description of project activity	NIL	NIL	NIL
Application and selection of methodologies and standardized baselines	--	--	--
- Application of methodologies and standardized baselines	NIL	NIL	NIL
- Deviation from methodology and/or methodological tool	NIL	NIL	NIL
- Clarification on applicability of methodology, tool and/or standardized baseline	NIL	NIL	NIL
- Project boundary, sources and GHGs	NIL	NIL	NIL
- Baseline scenario	NIL	NIL	NIL
- Estimation of emission reductions or net anthropogenic removals	NIL	NIL	NIL
- Monitoring Report	NIL	NIL	NIL
Start date, crediting period and duration	NIL	NIL	NIL
Environmental impacts	NIL	NIL	NIL
Project Owner- Identification and communication	NIL	NIL	NIL
Others (please specify)	NIL	NIL	NIL
Total	NIL	NIL	NIL

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

D. Project Verification findings

D.1 Identification and eligibility of project type

Means of Project Verification	The project has taken reference of CDM methodology AMS-I.D, version 18 Grid Connected Renewable Electricity Generation.
Findings	1. Project activity is described through UCR approved PCN. 2. UCR project communication agreement clearly defines the Project Proponent and Project Aggregator.
Conclusion	The plant capacity is 0.25 MW. The UCR-approved format is used for description and the project meets the requirement of the UCR verification standard and UCR project standard. The UCR project communication agreement has been verified. Methodology referenced and applied appropriately describing the project type. The eligibility of the project aggregator is verified using the UCR communication agreement, Project correctly applies the verification standard, UCR project standard, and UCR regulations. The project activity is overall meeting the requirements of the UCR Verification standard and UCR project standard.

D.2 General description of project activity

Means of Project Verification	Document verification of detailed project reports (DPR), commissioning certificates, calibration reports, power plant and meter photographs, and joint metering reading reports (JMRs).
Findings	The project commissioning date is verified in accordance with the commissioning certificate.
Conclusion	Plant capacity was cross-checked with the purchase invoices that define the plant aggregate capacity. The total number of panels purchased was 657 of 380 Wp DC capacity. The description of the project activity is verified to be true as per the actual electricity generation from the solar plant based on the review of the emission reduction excel sheet, PCN, MR, commissioning certificate, DPR, and PPA.

D.3 Application and selection of methodologies and standardized baselines

D.3.1 Application of methodology and standardized baselines

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Means of Project Verification	The project has taken the reference of CDM methodology A.M.S I.D. CDM website is referred to check the latest version of the methodology. For the applicability mentioned in the PCN and MR, the commissioning certificate, and detailed project report documents were referred.
Findings	The methodology applied is applicable to the project activity.
Conclusion	The methodology applied is appropriate meeting the requirements of UCR and its standardized baseline. The methodology version is correct and valid. The referenced methodology is applicable to project activity.

D.3.2 Clarification on applicability of methodology, tool, and/or standardized baseline

Means of Project Verification	The documents reviewed are A.M.S I. D “Grid connected renewable electricity generation” version 18, UCR Program standard, and UCR Verification Standard.
Findings	The emission factor is taken as 0.9 tCO ₂ /MWh as per the UCR standard.
Conclusion	The emission factor considered for the calculation of the emission reductions is verified with the UCR Program Standard. The total installed electrical energy generation capacity of the project equipment does not exceed 15 MW thus meeting the requirement of a small-scale project.

D.3.3 Project boundary, sources, and GHGs

Means of Project Verification	Letter from CPCB dated 07/03/2016 No. B-29012/ESS(CPA)/2015-16. PCN section B.4.
Findings	Project boundary is appropriately defined in PCN version 02 which is the physical and geographical site of a powerhouse.
Conclusion	The project boundary is correctly defined in the revised PCN version 2.0. GHG source correctly identified and reported. The project meets the requirements of the UCR project standard, verification standard, and methodology requirements for GHG sources.

D.3.4 Baseline scenario

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Means of Project Verification	PCN section B.5 and general project eligibility criteria and guidance, UCR Standard.
Findings	The declared information is correct and verified.
Conclusion	The baseline scenario is appropriately described. The conservative value for emission for each vintage year during the crediting period has been considered. The baseline scenario is in accordance with the UCR project verification standard and UCR project standard.

D.3.5 Estimation of emission reductions or net anthropogenic removal

Means of Project Verification	Meter calibration reports, JMRS, and general project eligibility criteria and guidance, UCR Standard, page 4.
Findings	None.
Conclusion	The emission reduction calculation sheet attached with MR was rounded down for each vintage year. Monitoring parameters as reported adequately represents the parameters relevant to emission reduction calculation. The emission factor is as per UCR standards. Based on monitoring and emission reduction are correctly calculated and reported. The monitoring report meets the requirements of UCR project verification requirements.

D.3.6 Monitoring Report

Means of Project Verification	Meter calibration reports, JMRS, and general project eligibility criteria and guidance, UCR Standard, page 4. Energy Meters installed at site: <u>Main Meter</u>
--------------------------------------	--

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in



Check Meter



Findings

None.

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Conclusion	Calibration reports of all the meters provided by PP certify that errors are within permissible limits as per IEC 62053-22 and details are mentioned below.											
	<table><tr><th>Meter</th><th>Meter Sr. No</th><th>Calibration Date</th></tr><tr><td>Main Meter</td><td>0021000062</td><td>23/03/2021</td></tr><tr><td>Check Meter</td><td>0021000065</td><td>23/03/2021</td></tr></table>			Meter	Meter Sr. No	Calibration Date	Main Meter	0021000062	23/03/2021	Check Meter	0021000065	23/03/2021
	Meter	Meter Sr. No	Calibration Date									
	Main Meter	0021000062	23/03/2021									
	Check Meter	0021000065	23/03/2021									
The monitoring parameter reported in MR adequately represents the parameters relevant to emission reduction calculation. The calibration report ensures the accuracy of the data reported. The number of CoUs generation is calculated based on this accurately reported data. The calculation was done using an excel sheet where all the parameters were reported. The emission factor for electricity is as per UCR standard. In the monitoring report, emission reduction calculations are correctly calculated and reported. The monitoring report meets the requirements of UCR project verification requirements.												

D.4 Start date, crediting period, and duration

Means of Project Verification	PCN 2.0, MR, commissioning certificate, DPR, and JMRS documents were referred.
Findings	None
Conclusion	The start date of the project activity is 26/04/2021 which is the start date of electricity generation. Crediting period for this verification report is as per the monitoring report submitted by PP which is 26/04/2021 to 31/12/2022.

D.5 Positive Environmental impacts

Means of Project Verification	PCN 2.0
Findings	The declared information is correct and verified.
Conclusion	The positive environmental impact meets the requirement of the UCR verification standard and UCR project standard.

D.6 Project Owner- Identification and communication

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Means of Project Verification	PCN, communication agreement, MR, purchase order of solar PV panel, solar inverter, commissioning certificate, PPA.
Findings	The declared information is correct and verified.
Conclusion	The project owner was identified through a communication agreement signed between PP and PA. Also, a legal document like PPA clearly establishes the project owner. The identification and communication correctly meet the requirement of project verification and UCR project standard. Details of project owner; M/s Tara Solar Power PV Plant in Gujarat, India Address: V.P.O - Shamshi, Tehsil – Bhunter, Dist – Kullu, Himachal Pradesh, Pin Code-175126, India.

D.7 Positive Social Impact

Means of Project Verification	The project has provided temporary employment to local people during its installation and commissioning. Also, post-commissioning some of the people have been employed permanently and local people were engaged leading to social financial benefits. Overall social impact of project implementation is positive in the surrounding area.
Findings	--
Conclusion	The project has an overall positive social impact.

D.8 Sustainable development aspects (if any)

Means of Project Verification	Not Applicable
Findings	--
Conclusion	The project addresses SDG 7 Affordable and Clean Energy and SDG 13 Climate Action

E. Internal quality control:

- Due professional care has been taken while reviewing the submitted document.
- There is no conflict of interest as the verifier has no other engagement with either the aggregator or project owner directly or indirectly.
- Verification team consists of experienced personnel.

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

- Technical review is performed by an experienced and independent person.

F. Project Verification opinion:

Considering the above-mentioned verification conducted on the basis of UCR Protocol, which draws reference from UCR protocol standard and baseline, AMS.I.D – Grid connected renewable electricity generation (Version 18.0), the documents submitted during the verification including the PPA, DPR, Commissioning certificate, JMRs, and calibration reports, Project Concept Note (PCN 2.0), Monitoring Report, I am able to certify that the emission reductions from the project - 250 kW Ground Mounted Solar Power Project By M/s Tara Solar Power PV Plant (UCR ID – 156) for the period 26/04/2021 to 31/12/2022 amounts to 481 CoUs (481 tCO_{2e}).

G. Abbreviations

Abbreviations	Full texts
UCR	Universal Carbon Registry
CPCB	Central Pollution Control Board
JMR	Joint meter reading
HPSEBL	Himachal Pradesh State Electricity Board Ltd
PGCIL	Power Grid Corporation of India Limited
MR	Monitoring report
PCN	Project Concept Note
VR	Verification Report
VS	Verification Statement
DAA	Double Accounting Agreement
COD	Commercial Operation Date
PP/PO	Project Proponent / Project Owner
PA	Project Aggregator
PPA	Power Purchase Agreement
ER	Emission Reduction
CoUs	Carbon offset Units.
tCO _{2e}	Tons of Carbon Dioxide Equivalent
kWh	Kilo-Watt Hour
MWh	Mega-Watt Hour
kW	Kilo-Watt
MW	Mega-Watt
CDM	Clean Development Mechanism
SDG	Sustainable Development Goal
CAR	Corrective Action Request
CL	Clarification Request
FAR	Forward Action Request
GHG	Green House Gas
SPV	Solar Photovoltaic

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

PV	Photovoltaic
----	--------------

H. Competence of team members and technical reviewers

No.	Last name	First name	Affiliation	Technical Competence
1.	Amin	Shardul	Lead Verifier	Mr. Shardul Amin is post graduate in thermal system design and has more than 5 years of experience in the field of waste-to-energy, thermochemical conversion technologies, and emission study.

I. Document reviewed or referenced

No.	Author	Title	Provider
1	UCR	Communication Agreement	PA
2	Creduce	Project Concept Note	PA
3	Creduce	Monitoring Report	PA
4	Creduce	Avoidance of double accounting	PA
5	Creduce	Emission Reduction Excel	PA
6	PP	Power Purchase Agreement	PA
7	Yash Metrology	Calibration report 2021	PA
8	PP	Purchase order of Solar PV panel	PA
9	PP	Purchase order of Solar Inverter	PA
10	HPSEBL	Commissioning Date	PA
11	PP	Meter Photographs	PA
12	HPSEBL	JMR 2021-2022	PA

J. Clarification request, corrective action request, and forward action request

Table 1. CLs from this Project Verification

CL ID	Section no. :	Date:
Description of CL		
Project Owner's response		Date:
Documentation provided by Project Owner		
UCR Project Verifier assessment		Date:

Table 2. CARs from this Project Verification

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

CAR ID		Section no.		Date:
Description of CAR				
Project Owner's response				Date:
Documentation provided by Project Owner				
UCR Project Verifier assessment				Date:

Table 3. FARs from this Project Verification


FAR ID	XX	Section no.		Date: DD/MM/YY YY
Description of FAR				
Project Owner's response				Date: DD/MM/YY YY
Documentation provided by Project Owner				
UCR Project Verifier assessment				Date: DD/MM/YY YY

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

ANNEXURE I: Photographs of the Power Plant

A. Google Map Image of the Power Plant



B. Control Panel and Invertor



NATURELINK SOLUTIONS PRIVATE LIMITED



REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in



NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

A. Date of commissioning

	HIMACHAL PRADESH STATE LOAD DESPATCH CENTRE (an Apex body) GOVERNMENT OF HIMACHAL PRADESH	
No. HPLDS/SLDC-29/COD/Vol.-3/2021-22 3061-68		Dated: 03-08-2021
To		
M/s Tara Solar PV Power Plant, V.P.O. Shamshi, Tehsil Bhunter, Distt. Kullu (HP). E- mail: globalbajaj@yahoo.com		
Subject: 250 kWp Tara Solar Power PV Project Commissioning and achieving Commercial Operation - regarding issue of NOC thereof.		
Reference: Your office letter no. Nil dated: 16.07.2021.		
Sir,		
This is in reference to above referred letter vide which your firm have submitted the copy of generation data of trial run of 15 days w.e.f. 26.04.2021 to 10.05.2021 of 250 kWp Tara Solar PV Power Plant, duly vetted by Assistant Executive Engineer, Electrical Sub Division, HPSEBL, Bhunter Distt. Kullu (HP) and further verified by Superintending Engineer (Designs), Power House Electrical, HPSEB Ltd., Sundernagar, Distt. Mandi vide his office letter No. HPSEBL/PHE/Tara Solar-COD/2020-753-59 dated 30.06.2021 trial run w.e.f. 26.04.2021 to 10.05.2021 as per availability of irradiance for 250 kWp Tara Solar Power PV Project. On the scrutiny of record /data made available, it is found generally in order. Accordingly, HPSLDC conveys its NOC based upon the data submitted w.r.t. trial run of above project for certification of the Commercial date of Operation stipulated under Govt. of HP Notification No. MPP-F (1) 2/2005-XI Dated Shimla-2, 17th August 2016 and amended vide Notification No. MPP-F (I)-2/ 2005-XII dated Shimla-01, 10-10-2017. The above said NOC is issued subject to establishment of telemetry with HPSLDC/ALDC Control Centre, Shimla within a period of three months as per Clause 4.10.1 of HPEG, 2008 and its subsequent amendments.		
Yours Sincerely,		
 Superintending Engineer, HP State Load Despatch Centre, Govt. of HP, Totu, Shimla-11.		
Copy of above forwarded to the following for information and necessary action:		
1. The Chief Engineer (Energy), Directorate of Energy, Shanti Bhawan, Phase-III, Sector-6, New Shimla-171009. 2. The Chief Electrical Inspector, Block No.29, SDA Complex, Kasumpti, Shimla-9. 3. The Chief Engineer (Commercial), HPSEBL, Vidyut Bhawan, Shimla-171004. 4. The Chief Engineer (System Operation), HPSEBL, Vidyut Bhawan, Shimla-171004. 5. The Chief Engineer (Generation), HPSEBL, Sundernagar-175019 (HP). 6. The Superintending Engineer (PR&ALDC), HPSEBL, Totu, Shimla-11. 7. The Superintending Engineer (Designs), PHE, HPSEBL, Sundernagar, Distt. Mandi-175019.		
 Superintending Engineer, HP State Load Despatch Centre, Govt. of HP, Totu, Shimla-11.		
SLDC Complex, Totu, Shimla-171011 Phone: 0177-2838666, Telefax: 0177-2837649 GST No. 02AAAAH7757E1ZX Email: sehpslhc@gmail.com , cehpslhc@gmail.com , mdhpslhc@gmail.com , Web: www.hpslhc.com		