

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Verification Report

UCR ID:137



Title	1 MW Small Scale Morna Gureghar Hydro Electric Project By M/s Ashoka Sthapatya Pvt. Ltd.
Project Owner	M/S Ashoka Sthapatya Pvt. Ltd.
Project Location	Village- Gureghar, Taluka-Patan, District-Satara, Maharashtra, India. 17°17'40.3"N 73°50'06.3"E
Auditor	Mr. Shardul Amin, Lead Verifier, Email: audit@thenaturelink.in, Contact: +91- 7574804497, Naturelink Solutions Pvt. Ltd.
Date	16/05/2023

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

COVER PAGE	
Project Verification Report Form (VR)	
BASIC INFORMATION	
Name of approved UCR Project Verifier / Reference No.	Naturelink Solutions Pvt Ltd
Type of Accreditation	☐ CDM Accreditation ☐ ISO 14065 Accreditation ☒ UCR Approved Verifier
Approved UCR Scopes and GHG Sectoral scopes for Project Verification	Sectoral Scope: 01 Energy Industries
Validity of UCR approval of Verifier	May-2022 onwards
Completion date of this VR	16/05/2023
Title of the project activity	1 MW Small Scale Morna Gureghar Hydro Electric Project By M/s Ashoka Sthapatya Pvt. Ltd..
Project reference no. (as provided by UCR Program)	137
Name of Entity requesting verification service (can be Project Owners themselves or any Entity having authorization of Project Owners, example aggregator.)	Creduce Technologies Pvt. Ltd.
Contact details of the representative of the Entity, requesting verification service (Focal Point assigned for all communications)	Creduce Technologies Pvt. Ltd, Contact: +91-9016850742 Address: 2-O-13,14 Housing Board Colony, Banswara, Rajasthan - 327001, India.
Country where project is located	India
Applied methodologies (Approved methodologies by UCR Standard used)	AMS-I.D.: "Grid connected renewable electricity generation", version 18
Project Verification Criteria: Mandatory requirements to be assessed	☒ UCR Standard ☒ Applicable Approved Methodology ☐ Applicable Legal requirements /rules of host country

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

	☒ Eligibility of the Project Type ☒ Start date of the Project activity ☒ Meet applicability conditions in the applied methodology ☒ Credible Baseline ☒ Do No Harm Test ☒ Emission Reduction calculations ☒ Monitoring Report ☒ No GHG Double Counting ☐ Others (please mention below)
Project Verification Criteria: Optional requirements to be assessed	☒ Environmental Safeguards Standard and do-no-harm criteria ☐ Social Safeguards Standard do-no-harm criteria
Project Verifier's Confirmation: The <i>UCR Project Verifier</i> has verified the UCR project activity and therefore confirms the following:	Mr. Shardul Amin, the lead verifier of the Naturelink Solutions Pvt Ltd (UCR approved) has verified the UCR Project Activity "1 MW Small Scale Morna Gureghar Hydro Electric Project By M/s Ashoka Sthapatya Pvt. Ltd. ☒ The Project Owner has correctly described the Project Activity in the Project Concept Note 2.0 (dated 04/01/2023) including the applicability of the approved methodology A.M.S I. D and meets the methodology applicability conditions and has achieved the estimated GHG emission reductions, complies with the monitoring methodology and has calculated emission reductions estimates correctly and conservatively. ☒ The Project Activity is likely to generate GHG emission

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

	reductions amounting to the estimated 4955 tCO₂e, as indicated in the PCN, which are additional to the reductions that are likely to occur in absence of the project activity and complies with all applicable UCR rules, including ISO 14064-2 and ISO 14064-3. ☒ The Project Activity is not likely to cause any net-harm to the environment and/or society ☒ The Project Activity complies with all the applicable UCR rules and therefore recommends UCR Program to register the Project activity with above mentioned labels.
Project Verification Report, reference number and date of approval	Verification Report UCR Project ID: 137 Date: 16/05/2023
Name of the authorised personnel of UCR Project Verifier and his/her signature with date	 Mr. Shardul Amin, Lead Verifier, Naturelink Solutions Pvt. Ltd Date : 16/05/2023

Project Verification Report

A. Executive Summary

The verification work has been contracted by project aggregator Creduce Technologies Pvt Ltd to perform an independent verification of its UCR project titled “**1 MW Small Scale Morna Gureghar Hydro Electric Project By M/s Ashoka Sthapatya Pvt. Ltd. UCR approved project ID:137**”, to establish number of CoUs generated by project over the crediting period from 17/04/2021 to 31/12/2022 (both days included).

Verification for the period : 17/04/2021 to 31/12/2022

In my opinion, the total GHG emission reductions over the crediting/verification period stated in the Monitoring Report (MR), submitted to me are found to be correct and in line with the UCR guidelines.

The GHG emission reductions were calculated on the basis of UCR Protocols which draws reference from, Standard Baseline, AMS. I. D – Grid connected renewable electricity generation (Version 18.0). The verification was done remotely by way of video calls, phone calls and submission of documents for verification through emails as per UCR guidelines.

I am able to certify that the emission reductions from the 1 MW Small Scale Morna Gureghar Hydro Electric Project By M/s Ashoka Sthapatya Pvt. Ltd., UCR (UCR ID – 137) for the period 17/04/2021 to 31/12/2022 amounts to **4955 CoUs (4955 tCO₂e)**.

Scope

The scope of the verification is the independent, objective review and ex-post determination of the monitored reductions in GHG emission by the project activity.

1. The quality of data management and records of underlying data;
2. Completeness and accuracy of calculations and baseline emission reports;
3. Proper inclusion and documentation of all project locations,
4. Correct application of offset rules for filling Baseline Period data gaps;
5. Other data, methods and procedures deemed necessary to establish the accuracy of emission reductions.
6. Agreement stating Assurance to avoid double accounting for the project to be verified, along with required proof.

The project is assessed against the requirements of the UCR programme verification Guidance Document, UCR Standard, UCR Programme Manual and related rules and guidelines. Due professional care has been exercised and ethical conduct has been followed by the assessment team during the verification process. The verification report is a fair presentation of the verification activity. The validation of the project is not part of the present assignment and projects are deemed validate post-registration by UCR.

Description of the Project

As described in the Project Concept Note (PCN), the project activity involves the hydro project of installed aggregated capacity of 1 MW at Gureghar village, Satara district of Maharashtra, India. The details of the project activity are verified with the project report copy submitted for verification. The technical specification of the installed turbine is mentioned below;

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Turbines	
Type	Vertical Kaplan
Numbers	1
Capacity	1000 KW each
Rated Head	22 m
Estimated Efficiency	88 %
Rated Discharge	5.2 m ³ /s
Generator	
Type	Salient Pole Sync Alternator
No. of Units and Rating	One, 3 Phase, 1500 kVA
Voltage Rating	6.3 kV
Synchronous Speed	500 rpm

As mentioned in the Monitoring Report and Emission Reduction Calculation sheet submitted for verification, the project replaces anthropogenic emissions of greenhouse gases (GHGs) estimated to be approximately **4955 tCO₂e** for the said period under verification, there on **5507 MWh** amount of electricity from the generation mix of power plants connected to the Indian electricity grid, which is mainly dominated by the fossil-fuel based power plant.

The project activity is a grid-connected renewable energy generation project having capacity of less than 15 MW. The project is a small-scale activity. The methodology applied in the Monitoring Report is verified against the A.M.S I. D “Grid connected renewable electricity generation” version 18.0.

Verified total emission reductions achieved through the project activity during the monitoring period is summarised below:

Summary of the Project Activity and ERs Generated for the Monitoring Period

Start date of this Monitoring Period	17/04/2021
Carbon credits claimed up to	31/12/2022
Total ERs generated (tCO ₂ e)	4955 tCO ₂ e
Project Emission	0
Leakage Emission	0

B. Project Verification team, technical reviewer and approver:

No.	Role	Last name	First name	Affiliation	Involvement in		
					Doc review	Off-Site inspection	Interviews
1.	Lead Verifier	Amin	Shardul	Naturelink Solutions Pvt Ltd. (UCR authorised verifier)	Yes	No	Yes

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

C. Means of Project Verification

Desk/document review

The project documents submitted to UCR approved verifier Naturelink Solutions Pvt was reviewed by the technical expert and validated by the lead verifier. The documents reviewed include verification of the legal status of individual project owner for consistency, project related documents like installation and commissioning of equipment used in project activity, environmental clearances from state or Central Pollution Control Board (CPCB), monitoring related parameters including measuring instruments and their calibration records for the crediting period etc.

The PCN is made available to the verifier post approval by UCR which is considered as validated documents and the content of validated PCN is considered as record wherever required. Further the communication agreement made between the project owner and project aggregator is document of UCR registry hence the project aggregator is treated as authorized representative of project owner. All the documents submitted by project aggregator to verifier is treated as documents submitted on behalf of the project owner.

The list of submitted documents is available in a subsequent section of this verification report under section “Document reviewed or referenced”-section I.

On-Site inspection- Not applicable.

Date of off-site inspection: DD/MM/YYYY to DD/MM/YYYY	Not applicable as per UCR guideline site visit not conducted for this verification activity.		
No.	Activity performed Off-Site	Site location	Date
1.			

Interviews: Not applicable

As per UCR guideline the site visit was not conducted during the course of verification and only online interviews are conducted.

No.	Interview			Date	Subject
	Last name	First name	Affiliation		
1.	Amol	Jadhav	Engineer, Ashoka Sthapatya Pvt. Ltd.	23/01/2023	Meter calibration, project overview.

Sampling approach: Not applicable

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Clarification request (CLs), corrective action request (CARs) and forward action request (FARs) raised

Areas of Project Verification findings	No. of CL	No. of CAR	No. of FAR
Green House Gas (GHG)			
Identification and Eligibility of project type	NIL	NIL	NIL
General description of project activity	NIL	NIL	NIL
Application and selection of methodologies and standardized baselines	--	--	--
- Application of methodologies and standardized baselines	NIL	NIL	NIL
- Deviation from methodology and/or methodological tool	NIL	NIL	NIL
- Clarification on applicability of methodology, tool and/or standardized baseline	NIL	NIL	NIL
- Project boundary, sources and GHGs	NIL	NIL	NIL
- Baseline scenario	NIL	NIL	NIL
- Estimation of emission reductions or net anthropogenic removals	NIL	NIL	NIL
- Monitoring Report	NIL	NIL	NIL
Start date, crediting period and duration	NIL	NIL	NIL
Environmental impacts	NIL	NIL	NIL
Project Owner- Identification and communication	NIL	NIL	NIL
Others (please specify)	NIL	NIL	NIL
Total	NIL	NIL	NIL

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

D. Project Verification findings

D.1 Identification and eligibility of project type

Means of Project Verification	The project has taken reference of CDM methodology AMS-I D, version 18 Grid Connected Renewable Electricity Generation.
Findings	1. Project activity is described through UCR-approved PCN. 2. UCR project communication agreement clearly defines the Project Proponent and Project Aggregator.
Conclusion	The UCR approved format is used for description and project meets the requirement of UCR verification standard and UCR project standard. UCR project communication agreement submitted to the verifier and the same has been verified. Methodology referenced and applied appropriately describing the project type. The eligibility of project aggregator is verified using UCR communication agreement, Project correctly applies the verification standard, UCR project standard and UCR regulations. The project activity is overall meeting the requirements of UCR Verification standard and UCR project standard.

D.2 General description of project activity

Means of Project Verification	The project activity involves the setting up of a run-of-river hydropower plant. The commissioning certificate and DPR are referred. The project capacity was verified through PPA, purchase order/ invoices of turbine and JMR provided. The power evacuation at the substation is confirmed by the electricity generation sheet.
Findings	1. Project Commissioning date is mentioned in the commissioning certificate. 2. Turbine Capacity is same as mentioned technical specifications. 3. Project implementation and sale of energy abide the power purchase agreement.
Conclusion	The description of the project activity is verified to be true based on the review of PCN, MR, Commissioning Certificate, Purchase Order Copies and Technical Specification sheet.

D.3 Application and selection of methodologies and standardized baselines

D.3.1 Application of methodology and standardized baselines

Means of Project Verification	Project has taken reference of CDM methodology A.M.S I.D. CDM website is referred to check the latest version of the methodology. For the applicability mentioned in the PCN and MR, the commissioning certificate, Detailed Project Report, and PPA documents were referred.
--------------------------------------	---

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Findings	The methodology applied is applicable for the project activity.
Conclusion	Methodology application is appropriate meeting the requirements of UCR and its standardized baseline. The methodology version is correct and valid. Referenced methodology is applicable to project activity.

D.3.2 Clarification on applicability of methodology, tool and/or standardized baseline

Means of Project Verification	The documents reviewed are A.M.S I. D “Grid connected renewable electricity generation” version 18, UCR Program standard, and UCR Verification Standard.
Findings	Emission factor calculated using the methodology is higher than UCR standard recommends.
Conclusion	The emission factor considered for the calculation of the emission reductions is verified with the UCR Program Standard. The total installed electrical energy generation capacity of the project equipment does not exceed 15 MW thus meeting the requirement of small-scale project.

D.3.3 Project boundary, sources and GHGs

Means of Project Verification	Letter from CPCB dated 07/03/2016 No. B-29012/ESS(CPA)/2015-16. PCN section B.4.
Findings	Project boundary is appropriately defined in PCN version 01 which is the physical and geographical site of powerhouse.
Conclusion	The project boundary is correctly defined in revised PCN version 01. GHG source correctly identified and reported. The project meets the requirements of UCR project standard, Verification standard and methodology requirements for a boundary, GHG source.

D.3.4 Baseline scenario

Means of Project Verification	PCN Section B.5 and General Project Eligibility Criteria and Guidance, UCR Standard.
Findings	The declared information is correct and verified.
Conclusion	The baseline scenario is appropriately described. The conservative value for emission is considered. The baseline scenario is in accordance with the UCR project verification standard and UCR project standard.

D.3.5 Estimation of emission reductions or net anthropogenic removal

Means of Project Verification	Joint Meter Reading Reports, and General Project Eligibility Criteria and Guidance, UCR Standard, page 4.
--------------------------------------	---

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Findings	None
Conclusion	Emission reductions are correctly calculated. The instruments are calibrated and hence the emission reduction is reported correctly and meets the requirements of the UCR verification standard and UCR project standard.

D.3.6 Monitoring Report

Means of Project Verification	Energy meter calibration reports, Joint meter reading reports, and General Project Eligibility Criteria and Guidance, UCR Standard, page 4. Energy meters installed at the site: Existing Main meter  Existing Check meter 
Findings	None

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Conclusion	Meter testing reports are provided PP.			
	Meter	Make	Sr. No	Calibration date
	Main	Elster	02874767	12/11/2020
	Check	Elster	02874766	
	As per Central Electricity Authority (Installation and Operation of Meters) (Amendment) Regulations, 2019 clause 14 (i)-b “All Interface Meters shall be tested on-site using accredited test laboratory for routine accuracy testing at least once in five years and recalibrated if required.			
The Calibration reports are verified with the available serial number of meters. The errors are within permissible limits.				
Monitoring parameters as reported through MR adequately represents the parameters relevant to emission reduction calculation. The number of CoUs generation is calculated based on this accurately reported data. The calculation was done using an excel sheet where all the parameters reported. The emission factor for electricity is as per UCR standard for electricity component. Based on monitoring and emission reduction calculations are correctly calculated and reported. The monitoring report meets the requirements of UCR project verification requirements				

D.4 Start date, crediting period and duration

Means of Project Verification	PCN and MR, Commissioning certificate, Detailed Project Report and PPA documents were referred.
Findings	Declared information is correct and verified.
Conclusion	The start date, crediting period and project duration are reported correctly and this meets the requirements of UCR verification standard and UCR project standard. Start Date – 17/04/2021 Crediting Period – 17/04/2021 to 31/12/2022

D.5 Positive Environmental impacts

Means of Project Verification	PCN
Findings	The declared information is correct and verified.
Conclusion	The positive environmental impact meets the requirement of the UCR verification standard and UCR project standard.

D.6 Project Owner- Identification and communication

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Means of Project Verification	PCN, Communication Agreement, MR, Commissioning certificate, Power Purchase Agreement.
Findings	The declared information is correct and verified.
Conclusion	The project owner identified through communication agreement signed between PP and PA. Equipment purchase order and commission verified. Also, a legal document like Power Purchase Agreement clearly establishes the project owner. The identification and communication correctly meet the requirement of project verification and UCR project standard.

D.7 Positive Social Impact

Means of Project Verification	The project has provided temporary employment to local people during its installation and commissioning. Also, post-commissioning some of the people have been employed permanently and local people were engaged leading to social and financial benefits to the surrounding. Overall social impact of project implementation is positive in the surrounding area.
Findings	--
Conclusion	The project has overall positive social impact.

Sustainable development aspects (if any)

Means of Project Verification	Not Applicable
Findings	--
Conclusion	The Project has capability to address SDG 7 Affordable and Clean Energy and SDG 13 Climate Action

E. Internal quality control:

- Due professional care has been taken while reviewing the submitted document.
- There is no conflict of interest as the verifier has no other engagement with either the aggregator or project owner directly or indirectly.
- Verification team consists of experience personnel.
- Technical review is performed by experienced and independent person.

F. Project Verification opinion:

Considering the above-mentioned verification conducted on the basis of UCR Protocol, which draws reference from UCR Protocol Standard Baseline, AMS.I. D – Grid connected renewable electricity generation (Version 18.0), the documents submitted during the verification including the data, Project Concept Note (PCN) / Monitoring Report (MR), I am able to certify that the

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

emission reductions from the project - 1 MW Small Scale Morna Gureghar Hydro Electric Project By M/s Ashoka Sthapatya Pvt. Ltd. (UCR ID – 137) for the period 17/04/2021 to 31/12/2022 amounts to **4955 CoUs (4955 tCO₂e)**.

G. Abbreviations

Abbreviations	Full texts
UCR	Universal Carbon Registry
CPCB	Central Pollution Control Board
PGCIL	Power Grid Corporation of India Ltd.
MSEDCL	Maharashtra State Electricity Distribution Co. Ltd.
MR	Monitoring report
PCN	Project Concept Note
VR	Verification Report
VS	Verification Statement
DAA	Avoidance of Double Accounting Agreement
COD	Commercial Operation Date
PP/PO	Project Proponent / Project Owner
PA	Project Aggregator
PPA	Power Purchase Agreement
ER	Emission Reduction
CoUs	Carbon offset Units.
tCO ₂ e	Tons of Carbon Dioxide Equivalent
kWh	Kilo-Watt Hour
MWh	Mega-Watt Hour
kW	Kilo-Watt
MW	Mega-Watt
CDM	Clean Development Mechanism
SDG	Sustainable Development Goal
CAR	Corrective Action Request
CL	Clarification Request
FAR	Forward Action Request
GHG	Green House Gas
HEP	Hydro Electric Power

H. Competence of team members and technical reviewers

No.	Last name	First name	Affiliation	Technical Competence
1.	Amin	Shardul	Lead Verifier, Naturelink Solution Pvt Ltd.	Mr. Shardul Amin is post graduate having more than 5 years of experience in the field of waste to energy, thermochemical conversion technologies and emission study.

I. Document reviewed or referenced

No.	Author	Title	Provider
-----	--------	-------	----------

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

1	UCR	Communication Agreement	PA
2	Creduce	Project Concept Note	PA
3	Creduce	Monitoring Report	PA
4	Creduce	Avoidance of double accounting	PA
5	Creduce	Emission Reduction Excel	PA
6	MSEDCL	JMR (2021- 2022)	PA
7	Elster	Meter Calibration	PA
8	MSEDCL	PPA	PA
9	MSEDCL	Commissioning Certificate	PA
10	PP	DAA	PA

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

J. Clarification request, corrective action request and forward action request

Table 1. CLs from this Project Verification

CL ID	XX	Section no. :		Date:
Description of CL				
Project Owner's response				Date:
Documentation provided by Project Owner				
UCR Project Verifier assessment				Date:

Table 2. CARs from this Project Verification

CAR ID	XX	Section no. :		Date:
Description of CAR				
Project Owner's response				Date:
Documentation provided by Project Owner				
UCR Project Verifier assessment				Date:

Table 3. FARs from this Project Verification

FAR ID	XX	Section no.		Date: DD/MM/YY YY
Description of FAR				
Project Owner's response				Date: DD/MM/YY YY
Documentation provided by Project Owner				
UCR Project Verifier assessment				Date: DD/MM/YY YY

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

ANNEXURE I: Photographs of the power plant



NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in



NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Date of grid synchronization

MAHAVITARAN
Maharashtra State Electricity Distribution Co. Ltd.
(A Govt. of Maharashtra Undertaking)
CIN : U40109MH20055GC153645

PHONE NO : 02162-244640
FAX NO : 02162-245541
E-mail : sesatara@mahadiscom.in
Website : www.mahadiscom.in

Office of the Superintending Engineer
Administrative Building, Vidyut Bhavan,
1st floor, Krishnanagar,
Satara – 415 003

Ref: SE/STRC/T/SHP/01MW/Ashoka Sthapatya/21-22/
To, No 035777 Date:- 09 JUN 2021

M/s. Ashoka Sthapatya Pvt. Ltd.,
At Morana (Gureghar),
Tal - Patan Dist- Satara

Sub: - Commissioning and Synchronization certificate of 01 MW Small Hydro power plant with start-up power 85KW / 100 KVA in respect of 'M/s. Ashoka Sthapatya Pvt. Ltd., at Morana (Gureghar), Tal - Patan Dist- Satara on 33 KV Voltage Level

Ref: - 1] CE/BMTZ/Tech/DYEE II/1564 Dt. 20.05.2019 & 2708 Dt. 13.10.2020
2] MSETCL/ CO/STU/302B/B_GC/287/9486 Dt. 01.09.2018 &
MSETCL/ CO/STU/B_GC/EXTN_1/298/08119 Dt. 22.10.2019 &
MSETCL CO/STU/B_GC/EXTN_2/Lockdown/22 Dt. 01.06.2020.
MSETCL CO/STU/B_FGC/ 298/00102 Dt. 15.01.2021.
3] Consumer's appli. No. 012 Dated . 26.12.2019
4] SE/TQA/HTC/AEEI/17 Dated. 10.04.2019
5] TOL SE/STRC/ HTC-new/Startup power/Ashoka Sthapatya/(19-20)/01611
Dt. 17.02.2020
6] Approval from CE (DIST)-CE(Dist)/Co-ord cell/ M/s Ashoka Sthapatya Pvt.
Ltd/13135 Dt. 13.08.2020.
7] Consumer's Consent letter No. 015 Dt. 06.08.2020 -
8] TOL SE/STRC/HTC-New/Case No. 41/04500 Dt. 21.08.2020.
9] EI Charging Permission No. 05E527002810202080318/ Dt. 28.10.2020
10] EE/KRD/T/5977 Dt.04.11.2020
11] ASPL/Morana Hydro/MSEDCL/2020/22 Dt. 12.11.2020
12] SE(TQA)/ Pune/T/ 00229 Dt. 17.12.2020.
13] Release Order for only Startup Power SE/STRC/T/HTC/Startup power/ Ashoka
Sthapatya/20-21/410 Dt.19.01.2021
14] Synchronization Permission CE/MSLDC/EA/ASPL/No.00467 Dt.03.03.2021.
15] Permission to Commission CE/RE/SHP/PTC/7317 Dt.26.03.2021.
16] SE/STRC/Tech/Ashoka Sthapatya/Startup Power/6641 Dt. 16.12.2020.
17] E-mail from EHV Dt. 06.04.2021
18] SE/STRC/T/SHP/1 MW/Ashoka Sthapatya / 20-21/2210 dt.08.04.2021.

This is to certify that 01 MW Small Hydro power plant with start-up power 85KW / 100 KVA in respect of 'M/s. Ashoka Sthapatya Pvt. Ltd., at Morana (Gureghar), Tal - Patan Dist- Satara is commissioned and synchronized with the Grid successfully on date 17.04.2021 at 12.45 Hrs.

(Gautam N Gaikwad)
Superintending Engineer
MSEDCL, Satara Circle

Copy swr To:
1] The Chief Engineer (Commercial) MSEDCL, Prakashgad, Bandra (E) Mumbai
2] The Chief Engineer (Renewable Energy) MSEDCL, Prakashgad, Bandra (E) Mumbai
3] The Chief Engineer (BMTZ) MSEDCL, Baramati Zone Baramati
4] The Director General MEDA Pune for favor of information, please.
.....Detailed Commissioning report is being submitted separately.

NATURELINK SOLUTIONS PRIVATE LIMITED

REG.OFFICE: H. NO. 6/121/1A, PLOT NO. G-1, VAIRAGI NI WADI, NEAR DELHI GATE SURAT – 395007
Email: audit@thenaturelink.in

Google map photos

