

Verification Report for

: KIL Waste Heat to Power Project, India. Project

UCR Project ID

Name of Verifier	SQAC Certification Pvt. Ltd.
Date of Issue	January 17, 2024
Project Proponent	M/s Kamachi Industries Ltd (KIL)
UCR Project Aggregator	Global Green Energy LLC
Work carried by	Mr. Santosh Nair
Work reviewed by	Mr. Praful Shinganapurkar

Summary:

SQAC Certification Pvt. Ltd. has performed verification of the "KIL Waste Heat to Power Project, India". The project activity is the utilisation of waste heat of flue gases generated in DRI kilns of sponge iron plant of Kamachi Industries Ltd (KIL) in power generation. The power produced is used actively at the sponge iron plant of KIL and the surplus power generated by the Waste Heat Recovery Boilers (WHRB) plant is consumed by the adjoining steel plant owned by KIL which is within the same premises as the WHRB plant. The project activity results in reduced carbon emissions by displacing equivalent amount of power generation in Southern Region grid connected power stations in India.

The project activity meets the following UN SDG's:













Verification for the period: **01/01//2018 - 31/12/2022** (5 years 0 months)

The GHG emission reductions were calculated on the basis of UCR Protocols which draws reference from, UCR Protocol Standard Baseline, CDM UNFCCC Methodology, ACM0012 Waste energy recovery Version 6.0. The verification was done was done remotely by way of video calls / verification, phone calls and submission of documents for verification through emails.

Accredited by 5 Jupiter House, Callera Park, Aldermaston, Reading Berkshire RG7 8NN, United Kingdom (UK). India Office: Off. No. 4, Fifth Floor, Buildmore Business Park, New Canca Bypass Road, Khorlim, Mapusa, Goa – 403 507

Web: www.sqac.in

Email: info@sqac.in Tel: 7219716786 / 87



SQAC is able to certify that the emission reductions from KIL Waste Heat to Power project, India, (UCR ID – 380) for the period **01/01/2018** to **31/12/2022** amounts to **2,14,630** CoUs (**2,14,630** tCO₂eq)

Detailed Verification Report:

Purpose:

The project activity entails utilisation of waste heat of flue gases generated in DRI kilns of sponge iron plant of Kamachi Industries Ltd (KIL, formerly Kamachi Sponge & Power Corporation Limited, Project Proponent or PP hereafter) in power generation. The power produced is used actively at the sponge iron plant of KIL. Apart from the utilization of the power at the sponge iron plant, the surplus power generated by the Waste Heat Recovery Boilers (WHRB) plant is consumed by the adjoining steel plant owned by KIL which is within the same premises as the WHRB plant. The project activity started commercial production from 29/12/2007 (contract date with AREVA, the technology supplier in the project activity).

Power from the WHRB plant, displaces equivalent amount of power from the Tamil Nadu Electricity Board (TNEB) grid, which is part of Southern Region (SR) grid in India. The project activity results in reduced carbon emissions by avoiding generation of this power in grid connected power stations.

KIL has set up 04 nos. DRI kilns of 100 TPD each at its sponge iron production unit. Annual sponge iron production is ~120000 TPA. Each of the kilns generates ~25000 Nm³/hr of high temperature flue gases. The temperature of flue gases from the kiln leaving After Burner Chamber (ABC) is at ~950-1000 °C. This waste heat of flue gases is utilised in the generation of steam in (WHRB), which is further expanded in a single bleed-condensing turbine of 10MW to generate power. Steam from 04 nos. WHRB is taken to the turbine through a common header.

In the absence of the project activity, KIL would draw power from TNEB grid, which in turn generates power from fossil fuel power plants. The project activity thus displaces equivalent amount of power generation in SR grid connected power stations. The useful energy generated from the utilization of waste energy carried in the project activity is for generation of electricity.

The project activity is displacing an estimated total net electricity generation i.e., 238480 MWh from the Indian grid system, which otherwise would have been generated by the operation of fossil fuel based grid-connected power plant. The estimated annual average CO₂e emission reductions by the project activity is expected to be 214630 tCO₂e, whereas actual emission reduction achieved during the first CoU period shall be submitted as a part of the initial UCR monitoring and verification activity.











Location of project activity:


Plot No : 86, 116-119 & 123-125

Village : Pappankuppam Taluk : Gummudipundi

District : Tiruvallur
State : Tamil Nadu,

Country : India Longitude : 79.57 E Latitude : 13.09 N







Scope:

The scope covers verification of emission reductions from the project - KIL Waste Heat to Power project, India, (UCR ID - 380).

Criteria:

Verification criteria is as per the requirements of UCR Standard.



Description of project:

The total installed capacity of the project activity is 10 MW and the auxiliary consumption as per the requirement of the auxiliary equipment at the WHRB plant is a maximum of 10% which is 1 MW. The balance of 7~8 MW of electricity generated by the WHRB plant is consumed by the adjoining steel plant owned by the PP which is within the same premises as the WHRB Plant.

KIL has installed 4X10 TPH Waste Heat Recovery Boilers (WHRBs) for utilising high temperature heat of flue gases from 4X100 TPD DRI kilns. DRI kilns, known as Direct Reduced Iron kilns by thermal systems, is a type of kiln used in the production of sponge iron wherein iron ore is reduced to iron in a reactor vessel, using reducing gases like hydrogen or carbon monoxide. The temperature of flue gases after 'After Burning Chamber' (ABC) is at 950-1000 °C.

Steam is generated at 67 kg/cm² and 485 $^{\circ}$ C and expanded in one single bleed-condensing turbine of 10MW to generate power. Each of the 04 kilns generates ~25000 Nm³/hr of high temperature flue gases. The temperature of flue gases from the kiln leaving After Burner Chamber (ABC) is at ~950-1000 $^{\circ}$ C.

This waste heat of flue gases is utilised in generation of steam in (WHRB), which is further expanded in a single bleed-condensing turbine of 10MW to generate power. Steam from 04 nos. WHRB is taken to the turbine through a common header.

Waste heat recovery boiler

Capacity	10 TPH						
Steam Pressure	67 kg/cm ²						
Steam Temperature	485 +- 5 deg C						
Nos.	04 Nos.						
Flue gas inlet temp.	950 deg C						
Flue gas inlet to ESP	175 deg C						

Turbine

Rated Capacity	10 MW	
Steam Inlet Pressure	64 ata	
Steam Inlet Temperature	480 deg C	
Nos.	1 nos.	
Bleed pressure for deaerator	4 ATA	



United Nations Sustainable Development Goals:

The project activity displaces Tamil Nadu Electricity Board (TNEB) power, part of SR grid, which is predominantly fossil fuel based. In the absence of the project activity equivalent amount of power generation would have taken place through fossil fuel dominated power generating stations.

Positive contribution of the project to the following Sustainable Development Goals:

Development Goals	Targeted SDG	Target Indicator (SDG Indicator)
13 CLIMATE ACTION SDG 13: Climate Action	13.2: Integrate climate change measures into national policies, strategies and planning Target: 214630 tCO ₂ for this monitored period	13.2.1: Number of countries that have communicated establishment or operationalization of an integrated policy/ strategy/ plan which increases their ability to adapt to the adverse impacts of climate change, and foster climate resilience and low greenhouse gas emissions development in a manner that does not threaten food production (including a national adaptation plan, nationally determined contribution, national communication, biennial update report or other)
7 AFFORDABLE AND CLEAN ENERGY SDG 7: Affordable and Clean Energy	By 2030, increase substantially the share of non fossil energy in the global energy mix Target: 238480 MWh supplied per	The project activity helps reducing GHG emission in power generation in the grid, which is primarily fossil fuel based
	annum	
8 DECENT WORK AND ECONOMIC GROWTH SDG 8: Decent Work and Economic Growth	8.5: By 2030, achieve full and productive employment and decent work for all women and men, including for young people and persons with disabilities, and equal pay for work of equal value	8.5.1: Average hourly earnings of female and male employees, by occupation, age and persons with disabilities
	Target: Training, O&M staff	



Level of Assurance:

The verification report is based on the on the information collected through interviews conducted over video calls / phone calls, supporting documents provided during the verification, Project Concept Note (PCN) / Monitoring Report (MR), submitted to SQAC. The verification opinion is assured provided the credibility of all the above.

Verification Methodology:

Review of the following documentation was done by SQAC Lead Verifier, Mr. Santosh Nair, who is experienced in such projects.

Documentation Verified:

- Project Concept Note (PCN)
- Monitoring Report (MR)
- Commissioning Certificate
- Calibration report
- Data provided upon request of all the documents of the related projects.

Sampling:

Not applicable

Persons interviewed:

Mr. Umashankar : M/s Kamachi Industries Ltd (KIL).
 Mr. Umanath : M/s Kamachi Industries Ltd (KIL).

Documentation Verified:

- Project Concept Note (PCN)
- Monitoring Report (MR)
- Calibration Reports
- Commissioning Certificate
- Energy Meter Log Sheets



To Whom it May concern

Certified that M/s. Kamatchi Sponge and Power Corporation Ltd., Gummidipoondi had Synchronized their 10 MW Power Plant with Tamil Nadu Electricity Board Grid at 33 KV level on 31.12.2007.

> 5mgm 3/3/08. S.MURALIDHARAN B.E.,

ASST. EXECUTIVE ENGINEER O&M/CEDC/N/TNEB PANJETTY - 601 204

Date: 03.03.2008 Place: Durainallur. To. Praveen.

GOVERNMENT OF TAMILNADU ELECTRICAL INSPECTORATE

From
The Chief Electrical Inspector
to Government,
Thiru Vi.Ka Industrial Estate,
Guindy, Chennai-600 032

Sirs.

To Thiru.Kamachi Sponge and Power Corporation Ltd. Papankuppam Village-602 201 Gummidipoondi, Kancheepuram District

Letter No.KPM.767/CEIG/D3/2007-1 Dated 2.11.2007

Indian Electricity Act 2003 and Indian Electricity Rules 1956 – New Co-generation Flant — HV/MV & LV Electrical Installation at Thiru Kamachi Sponge and Power Corp. — Program Village-edu. 2011 Gummanopocnot, Kancheepuram District — Paparikuppam Village-edu. 2011 Gummanopocnot, Kancheepuram District — Inspection under Rule 63 of Indian Electricity Rules, 1956 on 23.10.2007—Approved — accorded.

1) This office Letter No.KPM.767/CER3/03/2007 Dated 12.10/20076 2) Your letter No.Nil dated 15.10 2007 3) This office Letter No.KPM.767/CER/03/R52/03/2007 Dated 24.10/2007 4) Your letter No.AP/L/06//07-09I dated 3.10/2007

Under Rule 63 of Indian Electricity Rules, 1956, Approval is hereby accommission the Electrical Installations inspected on 23.10.2007 at the above prer detailed in Annexure subject to complying with the terms and conditions of the supplier.

Separate approval for 33 KV Switch yard with Power Transformer should be be obtained after producing TNEB approval for parallel operation.

The date of energisation of the installation may be intimated to this office

Under Rule 30(4) and 46 (3) of Indian Electricity Ruler 1356, the consumer is at all times solely responsible for the maintenance of the above installation in such a condition as to be free from danger.

(SQXX)

CHIEF ELECTRICAL INSPECTOR TO GOVERNMENT

Encl: Annexure containing List of Cleatrical Equipment

//True Copy/Forwarded//

ASSISTANT ELECTRICAL INSPECTION PRECHNICAL

Copy S: Thiru, Alfa Power Engineers Pvt.Ltd., Chennul-15

Copy to: The Superintending Engineer/ amil Nadu Electricity Board Chennai Electricity Distribution Circle/North/Chennai

Copy to: The Electrical Inspector/Kancheepuram
Copy to: The Assistant Electrical Inspector/Ponner
The Balance Inspection fees of Rs. 3740/- Itaa Leen of dated 12.10.207 (With Annexure) (With Annexure) sted in Bill No.315/2007-08

GOVERNMENT OF TAMILNADU Form GOVERNMENT ELECTRICAL STANDARDS LABORATORY Office of the Chief Electrical Inspector to Government Thiru V. Ka Industrial Estate Guindy, Chennai-32 Form D

CALIBRATION CERTIFICATE

Date of Calibration: 13.07.2018

Page 1 to 4

1 Personal Register (P/R) No.

Certificate No:2712/GESL/2018

: 989/2018

2 Name & Address of the Customer : M/s. Kamachi Industries Limited,

Partha Palayam Village, S.R,Kandigai Post, Gummidipoondi- 601 201.

3 Description and Identification of device under calibration(DUC)

Gummidpoonal-eu/ 2017.

3 Phase 4 wire Electronic Trivector meter,
Make: Larsen & Toubro Limited Mysore,
Model: ER 300 P, SI No. 07022884, Voltage11KV/110V, Current: 100/1A, Freqency:50 Hz.
Pulse: 5 Imp/Unil, Class:0.2s for Active,Cl: 0.5 for ReActive.
Mf. 1, Mfg. Jan-2007

: 10.07.2018

4 DUC Received on 5 Condition on receipt

6 Calibration Procedure Referance : VII of 003/CEIG/GESL/CPM

: Functional

RH: <70%

7 Environment conditions 8 Traceability details

Temperature: 23°C ± 2.5 °C

SL.No Standards used 1 3P Precision Measuring Instrument, Make: ZERA, Model : EPZ303-08, Sl.No: 050027197

Calibrated at/ Certificate Ref No. Yadhav Measurements Pvt Ltd. Udaipur, Rajasthan, India - 313 003. REF:YMPL/307728/98913

Valid upto 03.06.2019

All Measurement are traceable to the National/International Standards

68-31-5869 25-7-2018 Calibrated By (Tester I/II/III)





Issued by Junior-Electrical Inspector/ Assistant Electrical Inspector (Authorized Signatory)

GOVERNMENT OF TAMILNADU Form D GOVERNMENT ELECTRICAL STANDARDS LABORATORY Office of the Chief Electrical Inspector to Government Thiru VI, Ka Industrial Estate Guindy, Chennai-32

CALIBRATION CERTIFICATE

Certificate No: 1618/GESL/2021 Date of Calibration: .14.06.2021 & 15.06.2021.

1 Personal Register (P/R) No. 560/2021

2 Name & Address of the

: M/s. Kamachi Industries Limited, Survey No:86, 115-119, 123, Partha Palayam Village, S.R,Kandigai Post, Gummidipoondi-601 201.

3 Description and Identification of ice under calibration(DUC)

3 Phase 4Wire Electronic Trivector meter. 3 Phase 4Wire Electronic Trivactor meter, Make: Larsen & Toubro Limited Mysore, Model: ER 300 P, SI.No.07022891, Mf:1, Voltage:3*63.5V, PTR:-11KV/110V, Current: 800/1A, Freq;50 Hz, Jube Rate: 0.255 impl/brit Class:0.2s for Active ,0.5s for Reactive, Mfg: 2007.

Page 1 to 4

RH: <70%

: 11.06.2021 4 DUC Received on 5 Condition on receipt Functional

6 Calibration Procedure Referance: VII of 003/CEIG/GESL/CPM

: Temperature: 23°C ± 2.5 °C 7 Environment conditions

8 Traceability details

Calibrated at/ Certificate Ref No. Valid upto Standards used Zera India Pvt Ltd. Gandhi Nagar, Gujarat. REF: ZIPL/2021/ECL/001. 3P Precision Measuring Instrument, Make: ZERA, Model: EPZ303-08, SI.No: 050027197 06.01.2023

> All Measurement are traceable to the National/International Standards l. dy

0 00 12021 Checked By وه ۱۱۱/۱۱۱) Es. وه ۱ ع د الدهد (Tester I/۱۱/۱۱۱)

Issued by 2 4 204
Junior Electrical Inspector
(Authorized Signatory)

Cellifected (Circles (Circles



GOVERNMENT OF TAMILNADU Form GOVERNMENT ELECTRICAL STANDARDS LABORATORY Office of the Chief Electrical Inspector to Government Thirry Vi Ka Industrial Estate Guindy, Chennai-32

CALIBRATION CERTIFICATE

Certificate No: 1749/GESL/2022 Date of Calibration: .31.05.2022 & 01.06.2022.

Page 1 to 4

1 Personal Register (P/R) No. 2 Name & Address of the

Customer

: 637/2022

3 Description and Identification of device under calibration(DUC)

: 637/2022

'M's. Kamach Industries Limited,
NCP Division
Parthapalayam Village,
S.R.Kandigal Post,
Gummidipondi- 601 201.

'3 Phase 4/Wre Electronic Trivector meter,
Make: Larsen & Toubro Limited Mysore,
Model: ER 300 P. SI.No. 90142128 Mf-1,
Voltage:3*63.5V, PTR--11KV/110V, Current: 800/1A,
Freq.50 1tz, Pulse Rate:0 82500 impRWM,
0.82500 impRwarh, Class:0.2s for Active ,0.5s for
Reactive, Mfg: 2009.

4 DUC Received on

5 Condition on receipt

6 Calibration Procedure Referance: VII of 003/CEIG/GESL/CPM

7 Environment conditions 8 Traceability details

Standards used Three Phase Reference Standard, Make: ZERA, Model: COM 3003, SI.No: 050069528

: Temperature: 23°C ± 2.5 °C RH: <70%

Calibrated at/ Certificate Ref No.

Zera India Private Limited Gandhinagar, Gujarat - 382 024. Certificate No:ZIPL/2022/ECL/159.

11.03.2024.

All Measurement are traceable to the National/International Standards

68-38-36609 6.6.2022

CIENTA STANO

Phone : 044-2250 0184, 2250 0796, EXIn Nos. 114,145 Fax: 044-2250 0036Web site : www.tnei.tn.gov.in Email: eitech@in.gov.in, ceig@in.gov.in



KAMACHI INDUSTRIES LIMITED

10 MW NCP DIVISION - GUMMIDIPOONDI - 601201. DAILY ENERGY METER LOG SHEET

KIL-SID-MNT-EL-F-49-B2

01 12 22 NOTE: LAT I		NOTE: L&T M KWH X 1000 =	TR IN KWH C MWH READII	WH CONVERT TO 528 TIE BREAKER EADING NOTED								Import from 70 MW Via 6.6 KV		REMAKES	
	TUR. GEN	AUXILLARY	SPONGE			EXP	ORT		IMPORT						
TIME	MWH	MWH	MWH	MWH	MWH	MVARH	MVARH	MVAH	MWH	MVARH	MVARH	MVAH	MWH	MVAH	1 6
12.00 MN	86.43	72.93	58-84	01.88	9531	33.50	42.27	51.54	36.09	7049	3671	60.22	74.93	46.31	
01.00 AM		72.96			12.11	-	(1-2-)	212	3b-12	10.02	20.71	ho.2h			
02.00 AM		12.98	1						-	40.25	30-71	hr.:29			
03.00 AM		73.00	Y						26.16	70.28	30-11	hp.33			
04.00 AM		73.02							36.19	1000	30-11	60.3b			
05.00 AM		73.05							36.21	10.32	20:11	60-40			
06.00 AM		73.07							26.23		30.71	60.43			
07.00 AM		13-10	37 =						3616	70.36		60.47			
MA 00.80		73.13								76.38	30.71	60.51			
09.00 AM		73.17							3633	70-40	20.71	60.55			
10.00 AM		73.25	114							70.44	50.31	60.64			
11.00 AM		73.32					$\overline{}$		_	70.49	30.71	60.75			
12.00 MN		73.39	(Ca)						36 00	70.54	30.71	60.82			
01.00 PM		73.42	.0						36.50	-	30.31	F3.00			
02.00 PM		73.46	58.24	01.88					36.62	70.62	30-71	10.04			(+)
03.00 PM		72.49	58.84	01.91					26.67	76-67	26.71	60.91			
04.00 PM		72.50	58-29	01.96					36.71	100	30-71	61.04	-		
15.00 PM		73.53	58.91	01.98					36.76	70.77		6111			
06.00 PM		73.5h	20 11						24 4	70.79	20.11	61.15			-
17.00 PM		73,59								70.83		61.20			
08.00 PM		72.62							31.82	70-8h	3001	61.24			
09.00 PM		72,65							36.88	70-89	30.71	61.28			-
10.00 PM		73.68							36.91	70.90	30.71	61:33			_
11.00 PM		13.12							36 . 95		50	-,-5			
12.00 MN		13.15							36.98	70.99		61.42			-
TOTAL		0-82	0.07		el Land Ly				0.89	la La	30-11	61·H2			
NO. REV. IN Trv. Mtr			A SHFT SIGN V	No.	\$1		Elect HO	0	0.81 ScPN	,	TUPTRPTME				
OTE : ONCE	THE TRIVECTO	D METED WILL	B SHFT SIGN	1				5. 	31. FML	1	TO E GROSM				
WILL START	NH IT WILL RESE From "O" MWH	100000000000000000000000000000000000000	CSHETSON	1.,,			1.1			N	TUR FALLIRE				



KAMACHI INDUSTRIES LIMITED

10 MW NCP DIVISION - GUMMIDIPOONDI - 601201. DAILY ENERGY METER LOG SHEET

KIL-SID-MNT-EL-F-09-B2

30 06 2022 NOTE: LATE KWH X 1000			TR IN KINH CONVERT TO S2B TIE BREAKER MWH READING NOTED									Import from 76 Via 6.6 KV			
	TUR. GEN	AUXILLARY	SPO	NGE	EXPORT				IMPORT						
TIME	MWH	MWH	MWH	MWH	MWH	MVARH	MVARH	MVAH	MWH	MVARH	MVARH	MVAH	MWH	MVAH	- 1
12.00 MN	77-05	17.01	73-46	57-19	91.85	70.62	45.44	65-24	56.40	58-29	30.72	10.12	38-03	50.12	
01.00 AM	85.19	17.63	74.60	58-50	98.23	71-85	45.44	21.35							
02.00 AM	93.40	18.27	75.76	59.82	04.64	73.08	45.44	48.22							
03.00 AM	01.47	18.87	76.88	61-14	10-99	74.31	45.44	-							
04.00 AM	09.65	19.50	78.03	62.46	17.39	75.54	45.44	91.32							
05.00 AM	17.79	20.14	79.17	63-74	23.75	76.80	45.44	47-83							
MA 00.30	26.00	20.80	80.33	64-87	30.14		45.44								
MA 00.70	34.34	21:40	81.35	Ghilb	3686	-	4544	-							
08.00 AM	42.64	21.98	92-42	67.45	43.5t	2n-11	15:40	17.88							
09.00 AM	50.64	22.60	83-51	Be-68	19.80	81-94	45-41	24.40							
10.00 AM	58.67	22.04	84.65	70.00	56'th	23.07	45.44	20.86							
11.00 AM	blochb	22.87	18.28	71.40	62.25	84.42	4544	37.34							
12.00 MN	74.69	24.51	86.95	72.66	68.50	25-33	45.44	4376					-		
01.00 PM	89.22	26:13	68.06	73.95	74.30	2636	AC-UV	49.30							
02.00 PM	29,90	26.76	8919	75.14	80.31	37:50	45.64	5521							
03.00 PM	97.63	26.34	90.25	76.40	86-31	88.67	4544	6143							-
04.00 PM	65.35	26.94	91-34	77-68	92.34	89-84	4544	67.66							-
05.00 PM	13.56	27.57	92.52	79.03	98.74	91.06	4544	74.16							
06.00 PM	21.85	28.22	93.72	80.39	05 18	92.29	45.44	80.69							
07.00 PM		28.83	94.89	81-72	11.54	93.50	45-44	87.22							
08.00 PM	38.23	29.47	-	83.10	17-95	94-93	45.44	93.65							
19:00 PM	46.45		-	84-46	24.34	45.89	45.44	0016							0.00
	54.32	30.13	98-34	25.68	30-52	97-11	45-44	06.51							
11.00 PM	62.61	31.36	1. /	81.05	31.00	98-34	45-HH	13.10						_	
12.00 MN	10.95	32 -01	00:12	88-H3	13.49	99.57	45 HH	19.69							-
TOTAL	193.10	15.00	27.26		151.6h		- 17						_		
O. REV. IN	-).		19			-			TUP.TRP TIME				
WE HOM	E THE TRIVECTO AH IT WILL RESE FROM "O" MWH	R METER WILL IT THENT IT	SHELDON A	164	51		N. V		ts.PM	1	TUR FAILURE HRS:	\	-		

911				140
			AC	111
,	K L	١M	40	м
١.	IV			• •
	_	MI	BARS.	

KAMACHI INDUSTRIES LIMITED

10 MW NCP DIVISION - GUMMIDIPOONDI - 601201. DAILY ENERGY METER LOG SHEET

01/0	2019	NOTE : L&T MT KWH X 1000 = 1	R IN KWH CO WWH READIN	INVERT TO G NOTED				528 TIE 6	BREAKER				Import from 70 MW Via 6.6 KV		REMAKES
	TUR. GEN	AUXILLARY	SPO	NGE		EXPO	ORT			IMP	ORT				
TIME	MWH	MWH	MWH	MWH	MWH	MVARH	MVARH	MVAH	MWH	MVARH	MVARH	MVAH	MWH	MVAH	
12.00 MN	4613	88.38	8745	56:29	86.70	01-08	0111.	12.m	74-52	22.88	48:24	71:55	68/37	10.93	
MA 00.10	5336	89.06			93.25		04.14		1123	22.00	12				
2.00 AM	60.65	89.76	1000			04.04									
3.00 AM	67.95	90.43				05 54									
4.00 AM	75.17	91.09		127	13.03					-					
5.00 AM	82.43	91.76	81.45	56.29		08:52		-							
6.00 AM	89.48	92.42	87.45	56.29	11111	29.95	0014								
7.00 AM	94.93	93-07	27.45	54.29	32-81	11.54	04-14	50-57							
E.CO AN	04.60	93.74	87-45	56.29	39.81	13.14	04:14	52.49							
9.00 AM	11.00	94-39	87.05	52.05	45.56	14-24	ra-14	63:34						\vdash	
10.00 AM	12.99	95.05	98.02	28.10	17-32	15-34	14/4	0414						\vdash	
11.00 AM	205	95-72	89-09	28.82	57-69	16.46	14.14	74.94						\vdash	
12.00 MN	73.05	96-40	90.17	59-35	(2.38	13.55	04-14	80-91						Н	
01.00 PM	39.449	97.04	91.20	60.51	67.60	18-34	04:14	80.81						Н	
02.00 PM	bc-97	97.70	92-24	11.02	72-43	19 99	04-14	89.52						\vdash	
03.00 PM	52.93	98-38	93-33	6287	77.62	19.86	04-14	95.58						\vdash	
04.00 PM	59.98	99.07	94.45	64.18	82 86	20-74	04-14	01.20						\vdash	
05.00 PM	61.54	99-78	95 60	65.4n	88.5	21.63	04 14	06.07							
06.00 PM	74-40	(0.40)	96.72	66,77	94 10	22 53	04 14	12.5%							_
07.00 PM	81-40	01.69	97 1	67.80	99-66	23.33	04-14	11.62					-0.		
08.00 PM	88-42	0 14	95.73	£9.10	C4-35	24-24	04-16	23.43							
09.00 PM	AF-03	02-A)	99-17	70.26	10:25	\$5.31	04.14	29.22.							
10.00 PM	03.78	03-08	(0.80)	1/ 38	16-25	Ab 34	04-14	85.01							
11.00 PM	11.85	03.78	02-02	72.72	22.45	27.40	04.14	41.28							
12.00 MN	19.88	0449	03.20	74.07	38.54		04.14								
TÓTAL	173.70	16:11	15.75		141-84			-							_
NO. REV. IN	1	1	0	/	1	- /				_	TUPTRPTIME				
TRV. MTR	E THE TRIVECTO		A SHIFT SIGN ,	1	\$1 . W	1	Elect.HC	00	St. PM.		TG & GRID SH			\vdash	
COME 100M	WHIT WILL DEC	TI THENT IT	B SHFT SIGN C	to	- 4/	W	N. N	-			TME				
WILL START	FROM "O" MWH		CSHFTSGN (200	7						TUR FALURE HRS:				



Applied methodologies and standardized baselines:

UCR Protocol Standard Baseline

SECTORAL SCOPE - 01 Energy industries (Renewable/Non-renewable Sources)

04 Manufacturing industries

TYPE III - Energy Efficiency

CATEGORY - ACM0012 Large-scale Consolidated Methodology - Waste energy recovery Version 06.0

The consolidated methodology is applicable to project activities implemented in an existing or Greenfield waste energy generation (WEG) facility converting waste energy carried in identified waste energy carrying medium (WECM) stream(s) into useful energy (i.e. power, mechanical or thermal) consumed in an existing or Greenfield recipient facility(ies) and/or supplied to the grid in the case of electricity generation. The WEG facility may be one of the recipient facilities.

Applicability of methodologies and standardized baselines

- This project is included under this methodology since it applies to project activities that generate electricity from waste heat or the combustion of waste gases in industrial facilities. It's also included within the UCR Standard Positive List of technologies (updated) and is within the large -scale CDM thresholds under the applied methodology.
- Project activity involves power generation with installed capacity of 10 MW. Regulations do not require the project activity to recover and/or utilize the waste energy prior to the implementation of the project activity; The methodology is applicable where waste pressure is used to generate electricity only and the electricity generated from waste pressure is measurable.
- The proposed project activity is a power generation project from waste heat from DRI kilns in a sponge iron plant. The project activity displaces Tamil Nadu Electricity Board (TNEB) power, part of SR grid, which is predominantly fossil fuel based.
- The methodology allows for the recipient facility to be same as the waste energy generation facility. The project site is the waste energy generation facility and the facility itself receives useful energy generated using waste energy under the project activity.

Use of electricity from the waste heat utilisation in the project activity displaces an equivalent amount of electricity that would have been generated (in the absence of the project activity), by grid connected fossil fuel fired power plants. The project activity therefore results in reductions of emissions that would have taken place in the baseline scenario, viz., non-utilisation of the waste heat of the flue gases from the DRI kilns.



Applicability of double counting emission reductions

The project activity has been registered as a CDM project activity (registration date of the project activity under CDM mechanism is 03/10/2007) in the past.

The project activity was commissioned on 29/12/2007. It has undergone 05 CDM verifications for emission reductions achieved and has resulted in the issuance of CERs. The last CDM verification was for the seventh monitoring period 01/10/2016 to 30/12/2017 which is also the last in the CDM crediting period from 31/12/2007 to 30/12/2017 and has resulted in the issuance of CERs.

The project activity is seeking CoUs under the UCR CoU Standard/Program for the period 01/01/2018-31/12/2022 and hence there is no double counting issue of carbon credits for the said vintage period. Additionally, the same has been stated in the undertaking provided in the Double Counting Avoidance Assurance Document (DAA) by the PP.

The CDM project activity is as follows:

UNFCCC CDM Title	KSPCL Waste Heat to Po	wer project, India						
CDM ID	1151							
Host Parties	M/s Kamachi Sponge & Power Corporation Limited (KSPCL)							
Sectoral Scopes	1 : Energy industries (renewable - / non-renewable sources)							
Methodology	ACM0004 ver. 2- Consolidated methodology for waste gas and/or heat for power generation							
Other Details	CDM Registration Date	03/10/2007						
	Crediting Period	31/12/2007 – 30/12/2017 (Fixed)						
	Monitoring Period: 31/12	/2007-31/03/2008						
	CERs Issued: 3506							
	Monitoring Period: 01/04	/2008-31/03/2009						
	CERs Issued: 16545							
	Monitoring Period: 01/04	/2009-31/03/2010						
Prior Issuance of CDM	CERs Issued: 22905							
credits	Monitoring Period: 01/04	/2010-31/08/2011						
	CERs Issued: 31705							
	Monitoring Period: 01/09	/2011-31/12/2012						
	Awaiting CERs Issuance							



Agreement for Double Counting Avoidance from Proponent has been provided duly signed on 08/01/2024

Project boundary, sources and greenhouse gases (GHGs)

The spatial extent of the project boundary comprises the waste heat or gas sources, captive power generating equipment, any equipment used to provide auxiliary heat to the waste heat recovery process, and the power plants connected physically to the electricity grid that the proposed project activity will affect.

	Source	GHG	Included?	Justification/Explanation
Baseline		CO ₂	Included	Major source of emission
	Grid- connected	CH ₄	Excluded	Excluded for simplification. This is conservative.
	electricity	N ₂ O	Excluded	Excluded for simplification. This is conservative.
Project Activity	On-site fossil fuel consumption due to project activity Combustion of waste gas for	CO ₂	Excluded	Project activity entails use of waste heat of the flue gases from DRI kilns for power generation. Project activity does not entail use of fossil fuels in the project activity. The emissions from onsite diesel consumption are negligible and are excluded for simplification. This is conservative.
	electricity generation	CH ₄	Excluded	Excluded for simplification. This is conservative.
		N ₂ O	Excluded	Excluded for simplification. This is conservative.

Net GHG Emission Reductions and Removals

Thus, $ERy = BE_y - PE_y - LE_y$

Where:

 $ER_y = Emission reductions in year y (tCO₂/y)$

 BE_y = Baseline Emissions in year y (t CO_2/y)

 $PE_v = Project emissions in year y (tCO_2/y)$



 $LE_v = Leakage emissions in year y (tCO₂/y)$

Establishment and description of baseline scenario

Baseline emissions include only CO2 emissions from electricity generation in power plants that are displaced due to the project activity. The case established for the power required by the project activity, since it requires 1~2 MWh for its captive use, is less than the installed capacity of the equipment as per the methodology and its associated emissions quantification formula to be selected. The baseline emissions corresponding to electricity supplied by the project activity to recipient facilities is estimated for each recipient facility in accordance with the case established as above and in the case of the project activity is as follows:

(a) Case 1a: recipients whose project level electricity consumption is less than or up to the maximum capacity of the existing pre-project equipment at the recipient facility to use Equation (4)

$$BE_{EL,J,y} = \sum_i \left(EG_{i,j,y} \times EF_{Elec,i,j,y} \right)$$
 Equation (4) Where:
$$EG_{i,j,y} = \text{The power supplied by the project activity to the recipient facility } j,$$
 which in the absence of the project activity would have been sourced from baseline source i (e.g. ' gr ' for the grid or ' is ' for an identified source) during the year y as per the identified baseline scenario for recipient facility j (MWh)
$$EF_{Elec,i,j,y} = \sum_i \left(EG_{i,j,y} \times EF_{Elec,i,j,y} \right)$$
 The CO₂ emission factor for the baseline electricity source i (e.g. ' gr ' for the grid, and ' is ' for an identified source), corresponding to baseline scenario for the recipient facility j , during the year y (t CO₂/MWh)

(b) If the electricity displaced by the project activity in the recipient facility is supplied by a connected grid system, the CO2 emission factor of the electricity is modified from the UNFCCC CDM methodology and instead shall be determined following the guidance provided by the UCR CoU protocol for conservativeness.

Power Gen Cap Capacity	MW	10
Auxiliary Power Consumption	%	10%



Year	2018	2019	2020	2021	2022	Total
Total Generation						
(MWh)	54,192.62	50,446.56	28,171.78	35,158.33	35,416.36	2,03,385.65
Auxiliary						
Consumption (MWh)	5,266.22	4,829.78	3,125.10	3,349.77	3,608.06	20,178.93
Net Production						
(MWh)	48,436.57	47,110.49	47,921.32	47,969.46	47,042.55	2,38,480.39

Estimated Annual Baseline Emission Reductions: BE EL, j,y = EG BL,y X EF, CO2, GRID, y

BE $_{EL, j,y}$ = Baseline emission reductions in a year y at project site/recipient plant (j).

where:

EG _{BL,y} is calculated based on daily gross power generation and auxiliary power consumption in the power generation plant (recipient plant)

EG
$$_{BL,y}$$
 = EG $_{GEN,y}$ — EG $_{AUX,y}$.

where:

EG BL,y = Net power generation from turbine in year y (MWh/yr)

EG GEN,y= Gross power generation from turbine in year y (MWh/yr)

EG AUX,y= Auxiliary power consumption in power generation plant in year y (MWh/yr)

EF $_{Grid,CO2,y}$ = CO_2 emission factor of the grid in year y (t CO_2/MWh) as determined by the UCR Standard for the 2018-2022 period

A "grid emission factor" refers to a CO₂ emission factor (tCO₂/MWh) which will be associated with each unit of electricity provided by an electricity system. The UCR recommends an emission factor of 0.9 tCO₂/MWh for the 2018-2020 years as a fairly conservative estimate for Indian projects not previously verified under any GHG program. Also, for the vintage 2021-22, the combined margin emission factor calculated from CEA database in India results into same emission factors as that of the default value. Hence, the same emission factor has been considered to calculate the emission reduction.

No leakage is applicable under this methodology, hence, LE_v= 0



Issuance Period: 01/01/2018 to 31/12/2022

Year	2018	2019	2020	2021	2022	Total
Emission						
Reductions (tCO2)	43,592	42,399	43,129	43,172	42,338	2,14,630

Total Emission Reductions for the current crediting period =2,14,630 tCO₂eq (2,14,630 CoUs)

Conclusions:

Based on the audit conducted on the basis of UCR Protocol, which draws reference from UCR Protocol Standard Baseline, ACM0012 Waste energy recovery Version 6.0, the documents submitted during the verification including the Data, Project Concept Note (PCN) / Monitoring Report (MR), SQAC is able to certify that the emission reductions from the project - KIL Waste Heat to Power project, India (UCR ID - 380) for the period 01/01/2018 to 31/12/2022 amounts to 2,14,630 CoUs (2,14,630 tCO2eq)

Santosh Nair Lead Verifier (Signature)

Date: 17/01/2024

Praful Shinganapurkar Senior Internal Reviewer (Signature)